

TYPE-EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFT LANDING DOORS

Issued by Liftinstituut B.V.

Certificate nr. : NL 10-400-1002-114-05 Revision nr. -
Description of the product : Fire resistant central opening lift landing door
Trademark, type : Bulut Makina, Central opening lift landing door MER 2P
Name and address of the manufacturer : Bulut Makina Asansör San.ve Tic.Ltd.Şti.
Merkez Mahallesi Güney Yanyol Caddesi
No:17b/2 34956 Orhanlı
Tuzla – Istanbul, Turkey
Name and address of the certificate holder : Bulut Makina Asansör San.ve Tic.Ltd.Şti.
Merkez Mahallesi Güney Yanyol Caddesi
No:17b/2 34956 Orhanlı
Tuzla – Istanbul, Turkey
Certificate issued on the basis of the following requirements : Lifts Directive 95/16/EC; EN 81-58:2003
Test laboratory : FIRES, s.r.o.
Date and number of the laboratory report : June 29, 2010, FIRES-FR-089-10-NUNE
Date of type-examination : May 7, 2010


Classification : The performance criteria of the EN 81-58 covered are:

	E	EI	EW
Bulut Makina, Landing door MER 2P	120	60	60

Annexes with this certificate : Report belonging to the type-examination certificate;
Nr. NL 09-400-1002-114-05

Additional remarks : -

Conclusion : The Bulut Makina landing door MER 2P meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.



Issued in Amsterdam
Date of issue : July 15, 2010

LIFTINSTITUUT B.V.
Ir. V.M.A. Barendregt
Senior Officer Certification
& Technology

LIFTINSTITUUT B.V.
Drs. B. Mulder
Director Certification &
Inspection International