

TYPE-EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFT LANDING DOORS

Issued by Liftinstituut B.V.

Certificate nr. : NL 09-400-1002-114-02 Revision nr. -

Description of the product : Fire resistant side opening telescopic lift landing door

Trademark, type : Bulut Makina, Telescopic Lift Landing door TER 2P

Name and address of the manufacturer : Bulut Makina Asansör San.ve Tic.Ltd.Şti.
Merkez Mahallesi Güney Yanyol Caddesi
No:17b/1 34956 Orhanlı-Tuzla
Istanbul - Turkey

Name and address of the certificate holder : Bulut Makina Asansör San.ve Tic.Ltd.Şti.
Merkez Mahallesi Güney Yanyol Caddesi
No:17b/1 34956 Orhanlı-Tuzla
Istanbul - Turkey

Certificate issued on the basis of the following requirements : Lifts Directive 95/16/EC; EN 81-58:2003

Test laboratory : FIRES, s.r.o.

Date and number of the laboratory report : Not yet issued

Date of type-examination : March 23, 2009

Classification

The performance criteria of the EN 81-58 covered are:			
	E	EI	EW
Bulut Makina, Landing door TER 2P	120	90	60

Annexes with this certificate : Report belonging to the type-examination certificate;
Not yet issued.

Additional remarks : Reports are not yet issued.

Conclusion : The Bulut Makina landing door TER 2P meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.



Issued in Amsterdam
Date of issue : March 31, 2009

Liftinstituut B.V.
Senior Officer Certification
and Technology